



- ① BRASS BLADE
- ② BRASS GROUND PIN
- ③ MOULDED THERMOPLASTIC
- ④ "ULTRALX" AC90/MC or AC90 or MC LS 600V 90°C (CSA 22.2 No. 51-95 and UL 1569)
- ⑤ LOCKNUTLESS BOX CONNECTOR 1/2" K.O.
- ⑥ TAIL WITH STRIPPED ENDS

WHERE "cc" REPRESENTS COLOUR CODE I.E. "BK" IS BLACK
 WHERE "d" REPRESENTS CERTIFIED WIRING MATERIAL. I.E. "A" IS AC90
 WHERE "III" REPRESENTS LENGTH CODE I.E. "040" IS 04.0 METERS

**SYSTEM IS RATED FOR CONNECTION TO A GROUNDED 125/250V BRANCH CIRCUIT.
 MANUFACTURED WIRING SYSTEM UTILIZING 12 AWG APPROVED ULTRALX CABLE.
 INSTALLATION IN ACCORDANCE WITH THE CEC PART I OR THE NEC.
 ACCEPTABLE FOR USE IN ENVIRONMENTAL AIR SPACES OTHER THAN DUCTS OR PLENUMS
 PER CEC PART I 12-010(3) OR NEC 300-22(C)
 MEETS OR EXCEEDS: - CSA 22.2 NO. 203.1
 - UL 183**



125/250 Volt 20 Amp

CDN. PATENT - 1219307

U.S. PATENT - 4775802

ITEM	DESCRIPTION	PART#/POSITION	REMARKS
4	BARE	1	GROUND
	WHITE	2	NEUTRAL
	RED	3	LINE Cct.1
	BLACK	4	LINE Cct.2



100-5977 HAZELDEAN ROAD, OTTAWA, ONTARIO, CANADA K2S 1B9
 TELEPHONE (613) 836-0300 FAX (613) 836-0391
 TOLL-FREE (866) 233-5328 FAX (866) 933-1933
 e-mail: support@electeonline.com

OWNERSHIP OF DOCUMENTS
 This drawing and accompanying information as instrument of service are the property of **ELECTEC**.
 Reproduction or use in whole or in part in any form whether the work for which they are presented is executed or not is forbidden without the express written permission of **ELECTEC**.

DROP CABLE
 11242MTccIIId

DRAWN BY: J.Y.	APPROVED: D.H.	11242MT.9
DATE: 27-NOV-08	SCALE: N.T.S.	