



ACCEPTABLE MEANS FOR DISCONNECTING LUMINARIES
ACCEPTABLE FOR USE IN ENVIRONMENTAL AIR SPACES OTHER THAN DUCTS OR PLENUMS.
SYSTEM IS RATED FOR CONNECTION TO A GROUNDED 277V OR 347V BRANCH CIRCUIT.

MEETS OR EXCEEDS: - CSA 22.2 NO. 182.3
 - CSA 22.2 NO. 203.1
 - UL 1977
 - UL 183



277 OR 347 Volt 20 Amp

CDN. PATENT - 1219307 U.S. PATENT - 4775802

ITEM	DESCRIPTION	PART#/POSITION	REMARKS
6	GREEN	1	GROUND
	WHITE	2	NEUTRAL
	BLACK	3	LINE

100-5977 HAZELDEAN ROAD, OTTAWA, ONTARIO, CANADA K2S 1B9
 TELEPHONE (613) 836-0300 FAX (613) 836-0391
 TOLL-FREE (866) 233-5328 FAX (866) 933-1933
 e-mail: support@electeconline.com

OWNERSHIP OF DOCUMENTS

This drawing and accompanying information as instrument of service are the property of **ELECTEC**.
 Reproduction or use in whole or in part in any form whether the work for which they are presented be executed or not is forbidden without the express written permission of **ELECTEC**.

DUAL RECEPTACLE

100347RTRTcc

DRAWN BY: J.Y.	APPROVED: D.H.	100347RTRT.9
DATE: 21-OCT-08	SCALE: N.T.S.	